

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

| | |
|--|---|
| School District: | 73 - KamloopsThompson |
| School Name: | David Thompson |
| REQUIREMENT: Regular inspection and maintenance of HVAC systems | Yes/No: Yes |
| | Date of last inspection: 2021-03-31 |
| | Date of next inspection: 2024-03-29 |
| | Date and type of most recent maintenance: Preventative maintenance 2021-03-31, workorders as they come in |
| RECOMMENDATION: Increase supply of outside air | Yes/No: Yes |
| | Detail: 2 hour daily flush, increase supply of outside air as much as possible while maintaining thermal comfort |
| RECOMMENDATION: | |