

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	73 - KamloopsThompson
School Name:	Westmount Elementary
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: Click to enter a date.
	Date of next inspection: 2021-11-30
	Date and type of most recent maintenance: Preventative maintenance no record of last date, workorders as they come in
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: 2 hour daily flush, increase supply of outside air as much as possible while maintaining thermal comfort. Portable controls do not allow for a 2 hour flush, but are set to occupied mode for longer hours to provide longer ventilation. Outside air is maximized for each portable based on the outside air duct configuration.
RECOMMENDATION: Upgrade filtration, including installing MERV-	

District Contact for any Questions:	Name: Melissa McGarry, Manager of Health and Safety
	Phone Number: 250-374-0679
	Email: mmcgarry@sd73.bc.ca