

# VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information.

	73 - KamloopsThompson
School Name:	South Sahali Elementary
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2020-04-30
	Date of next inspection: 2023-05-31
	Date and type of most recent maintenance: Preventative maintenance 2020-04-30, workorders as they come in
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: 2 hour daily flush, increase supply of outside air as much as possible while maintaining thermal comfort. Portable controls do not allow for a 2 hour flush, but are set to occupied mode for longer hours to provide longer ventilation. Outside air is maximized for each portable based on the outside air duct configuration.
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade):  Merv 13 filters
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
RECOMMENDATION: Manage energy use and air distribution through building5 ( )]	

District Contact for any Questions:	Name: Melissa McGarry, Manager of Health and Safety
	Phone Number: 250-374-0679
	Email: mmcgarry@sd73.bc.ca