

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	73 - KamloopsThompson
School Name:	Sun Peaks ±SD Owned Portable
REQUIREMENT: Regular inspection and maintenance	New portable summer 2020, workorders as they come in
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes Detail: Portable controls do not allow for a 2 hour flush, but are set to occupied mode for longer hours to provide longer ventilation. Outside air is maximized for each portable based on the outside air duct configuration.
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes

District Contact SW